

270553-TC

Identification for Telecommunications Systems

PART 1: GENERAL

SCOPE OF WORK

- A. Work covered by this Section shall consist of furnishing labor, equipment, supplies, materials, and testing unless otherwise specified, and in performing the following operations recognized as necessary for the labeling of the telecommunications infrastructure as described on the Drawings and/or required by these specifications.
 - B. It is the intent of the MAA to create a Class 3 system of administration As per ANSI/TIA/EIA 606-A Standards. As such, all elements must be labeled with unique identifiers as described in the following sections.
 - C. This includes minimum requirements for the following:
 - 1. Labeling Communications Cabling
 - 2. Labeling Closet Hardware
 - 3. Labeling Conduit/Hand hole/Inner duct
 - 4. Labeling Patch Panel Jumpers
- 2 A. The Cable Labeling Hierarchy will be the following unless otherwise noted for all Cables, Inner Duct, Conduits, Hand holes, Patch cables and hardware inside plant and outside plant:
KB.109.1.1.1.1 whereas,
Building, Room, Rack Row number, Rack number, Panel number, Port

PART 2 - PRODUCTS

LABELS

- A. The size, color and contrast of all labels should be selected to ensure that the identifiers are easily read.
- B. All labels are to be mechanically printed, no hand printed labels allowed for any component.
- C. Labels should be visible during the installation of and normal maintenance of the infrastructure. Labels should be resistant to the environmental conditions at the point of installation (such as moisture, heat or ultraviolet light) and should have a design life equal to or greater than that of the labeled component.
- D. Provide vinyl substrate with a white printing area and black print. If cable jacket is white, provide cable label with printing area that is any other color than white, preferably orange or yellow – so that the labels are easily distinguishable.
- E. Labels shall be flexible vinyl or other substrates to apply easy and flex as cables are bent.
- F. Labels shall use aggressive adhesives that stay attached even to the most difficult to adhere to jacketing.

PART 4: EXECUTION

LABELING INSTALLATION

- A. Horizontal Copper Cable Labeling:
1. All horizontal cables shall be labeled with self-laminating marking tape, Brady ID-Pro labeler, Panduit LS7 labeler, or equivalent labeling system. Identification shall be as follows:
 2. At the TR end, the cables shall be labeled with the location of where the other end of the cable is terminated including room number, TO number, and jack position. Place label on a visible part of cable within 12" of termination point for ease of identification after termination.
 - a. Example: cable going to room 114, first TO, first jack position would be labeled as: 114-1A1. A cable in the second TO, third jack position would be 114-2A3.
 3. At the TO end, the cables shall be labeled 4" from termination with the following: TR – Rack.Patch Panel.Port. This shall be visible by removing outlet cover plate.
Example: TR Room 114, rack row 1, rack 1, patch panel 1, port 03 would be: 114 – 1.1.1.03
 - b. For voice cabling in older building with separate voice closets and no patch panels, include the TR and as much information as practical such as column, row, block number, and port number or pairs.
 4. For CATV coaxial drop cables, at the splitter or tap, the cables shall be labeled with the location where the other end of the cable is terminated including room number, TO number, and jack position. If not collocated with a TO, indicate room number at a minimum. Place label on a visible part of cable within 12" of termination point for ease of identification after termination.
 5. For coaxial cables at the TO, they shall be labeled 4" from termination with the room number where the splitter or tap is. This shall be visible by removing outlet cover plate.
- B. Telecommunications Outlet (TO) Labeling Scheme:
1. TO's are labeled alphanumerically in a clockwise rotation around the room. Typically, the first TO located to the left of the main entrance of the room is labeled 1A, followed by 2A, 3A, etc.
- C. Horizontal 110 and 66 Block Labeling for voice:
1. For 110 blocks, if the cables are for room terminations, label the appropriate corresponding space for the port with the room number, TO, and jack position.
Example: A cable going to room 114, first TO, first jack position would be labeled as: 114-1A1. A cable in the second TO, third jack position would be 114-2A3.

2. For 66 type blocks, if the cables are for room terminations, tag the cable with the room number, TO, and jack position with a loose paper tag that is easily accessible and readable.
Example: A cable in room 114, first TO, first jack position would be labeled as: 114-1A1. A cable in the second TO, third jack position would be 114-2A3.
 3. For tie cables between the rack and wallboard a 110 block or 66 block should always be used.
Example: Rack Row 1, Rack 1, patch panel 1, port 03 would be: 1.1.1.03
- D. Patch Panel Labeling:
1. For station cabling going to a TO, label each port on the patch panel with the room number, TO, and jack position.
Example: A cable in room 114, first TO, first jack position would be labeled as: 114-1A1. A cable in the second TO, third jack position would be 114-2A3.
Example: A cable going to a floor box TO labeled FB1A in room 114 in the second jack position would be labeled as: 114-FB1A2
- E. Vertical/Riser/Intrabuilding Copper Cable Labeling:
1. All riser cables shall be labeled with self-laminating marking tape, Brady ID-Pro labeler, Panduit LS7 labeler, or equivalent labeling system.
 2. At the TR, the copper riser cables shall be labeled with from/to, cable number, and count information on both ends.
Place label on a visible part of cable close to wiring block for ease of identification after termination.
 3. Label cabling every 50' along the length of the cable in open trays, and on each side of wall penetrations.
- F. Interbuilding/Campus/Backbone Copper and Fiber Cable Labeling:
1. All interbuilding cables shall be labeled permanently with from/to information, cable type and size, installation date, and installing contractor at each end, manhole, and pull box the cable passes through.
a. Example: From Building 500 to 300, a 24 stand fiber single mode cable would be:
500.105.1.1.1 - 300.100.2.1.3 – 24 ST SM
- G. Conduit, manhole and hand hole Labeling:
1. All interbuilding and intrabuilding Inner duct and conduit systems shall be labeled permanently with from/to information, Building, manhole/hand hole, bank, and conduit number.
Example: from/to 100.109.1.1-MH5W.3.1

- H. Cable Function Color Code
1. As an additional level of identification that allows a particular field type to be quickly located, Color Coded strips, icons, and so on will be installed on all terminated wall plates and block areas. Common equipment refers to PBX equipment, host computer, LAN's and multiplexers. Miscellaneous refers to maintenance alarms, security, paging systems, and other systems and circuits not an integral part of common equipment. Refer to the table below:

<u>Function</u>	<u>Color</u>
Auxiliary and miscellaneous circuits	Yellow
Common equipment	Purple
Customer side of network interface	Green
First level backbone	White
Horizontal cabling to workstations	Blue
Interbuilding backbone	Brown
Key telephone systems	Red
Network side of network interface	Orange
Second level backbone	Gray

<u>Building Reference</u>	<u>Identification</u>
901	Building 901
991	Building 991
TER	BWI Terminal
ARF	ARFF Building
KB	Kauffman Building
MAC	MAC Building
CR<nnn>	Cargo Building <number>
MCR	Mid-Field Cargo Building
PHG	Parking-Hourly Garage
PDA	Parking-Daily A Garage
PLA	Parking-Long Term A
PLB	Parking-Long Term B
PEX	Parking-Express Lot
PEP	Parking-Employee
PEA	Parking-Old ESP A
PEB	Parking-Old ESP B